

2.2 FINISHES

Finishes on metals not specified otherwise shall be provided as follows:

Metal	Finish
Corrosion- resisting Steel (Stainless Steel)	General- purpose Polished
Aluminum	Satin Anodic, Clear
Carbon Steel	Bright Chromium Plate
Copper Alloy (Brass)	Bright Chromium Plate
Zinc Alloy	Bright Chromium Plate

2.3 MANUFACTURED UNITS

2.3.1 Toilet Tissue Dispensers (Surface Mounted)

2.3.1.1 Type II, Roller Mounted on Single Continuous Bracket

2.3.1.2 Type II, Two Rolls of Tissue, Vertical Mount

CID A-A-2524, chromium plated steel. Holder shall consist of wall plate with one stationary or integral post and one hinged post. Fix a roller or bar to the stationary post. The holder shall be anti-pilfering type.

2.3.2 Combination Paper Towel Dispenser/ Waste Receptacle Units

Semi-recessed roll paper towel dispenser and waste receptacle shall be constructed of type 304 stainless steel, welded construction. Exposed surface shall have satin finish. Door with 9/16" inch 90 degree return shall be equipped with concealed, full length welded stainless steel piano hinge and cable door stop. Tumbler locks shall be keyed like other washroom accessories. Roll towel mechanism shall be adjustable to dispense preset lengths of paper towels from 1-1/2" inch core diameter rolls 8" inch to 9" inch wide and have automatic towel transfer feature. Waste receptacle shall be furnished with removable, leakproof rigid molded plastic waste container. Capacity: 8.6 gallons.

2.3.3 Sanitary Napkin Dispenser Units

Surface mounted units formed from stainless. Exposed surface shall have satin finish. Dispensers shall have a capacity of 30 napkins and 28 tampons. Dispensing mechanism shall be for complimentary operation. Tumbler locks keyed alike with other washroom accessories.

2.3.4 Sanitary Napkin Disposal Units for Use on Toilet Partitions

Units shall be the double-access type designed for mounting in a toilet partition cutout. Adjust units to fit partition thicknesses from one to 1 1/4 inch; projection into toilet compartments shall not exceed 2 inches. Fabricate units of stainless steel not lighter than 22 gage. Flanges shall be one-piece construction with no mitered or welded corners. Provide self-closing flap door with a full length piano hinge on each side of disposal units, and waste receptacle shall be removable from one side. Surfaces exposed to view after the units are installed shall have a satin finish.

2.3.5 Sanitary Napkin Disposal Units, Wall Mounted

Surface-mounted, closed containers with a fixed or folding utility shelf; the shelves and containers fabricated of stainless steel not lighter than 24 gage. The containers are approximately 9 inches wide by 11 inches high by 4 1/2 inches deep. The shelves shall be approximately 8 inches wide by 4 inches deep. Provide top container hinged door, and bottom hinged access door for removal of contents. Liners of the manufacturer's standard type shall be furnished. Surfaces that will be exposed after the units are installed shall have a satin finish.

2.3.6 Grab Bars

Surface mounted, stainless steel, 1 1/4 inches in diameter, with a nominal wall thickness of not less than 0.05 inch (18 gage), of the length and shape indicated, and with a nonslip finish. Grab bars and mounting devices shall be capable of withstanding a static load of 250 pounds at any point on the bar.

2.3.7 Soap Dispensers

Lavatory mounted with 4 inch stainless steel spout, 32 oz liquid soap container, removable plunger and spout. Provide with key to soap container.

2.3.8 Mirrors

Class 2, Style E, Grade 1, electrocopper plated, conforming to FS DD- M- 411, size as indicated. Satin finish trim.

2.3.9 Mop Rack with Shelf

Mop and Broom Holder with Utility Shelf: 36-inch-long unit fabricated of minimum nominal 0.05-inch-thick stainless steel with shelf; support brackets for wall mounting; three hooks for wiping rags; four spring-loaded, rubber hat, cam-type, mop/broom holders mounted on front of shelf; and approximately 1/4-inch-diameter, stainless-steel rod suspended beneath shelf for drying rags.

2.3.10 Seat Cover Dispenser

Stainless steel satin finish seat cover only, surface mounted and shall have a capacity of not less than 200 seat covers.

PART 3 - EXECUTION

3.1 INSTALLATION

Surfaces of fastening devices exposed after installation shall have the same finish as the attached accessory. Exposed screw heads shall be oval. Install accessories at the location and height indicated. Protect exposed surfaces of accessories with strippable plastic or by other means until the installation is accepted. After acceptance of accessories, remove and dispose of strippable plastic protection. Coordinate accessory manufacturer's mounting details with other trades as their work progresses. After installation, thoroughly clean exposed surfaces and restore damaged work to its original condition or replace with new work.

3.1.1 Surface Mounted Accessories

a. Unless indicated or specified otherwise, install accessories with sheet metal screws or wood screws in lead-lined braided jute, teflon or neoprene sleeves, or lead expansion shields, or with toggle bolts or other approved fasteners as required by the construction.

b. Provide concealed anchor plate behind wall finish and between wall studs for direct anchorage of grab bars to backing when anchorage to wall studs is not feasible. Install grab bars with fasteners provided by accessory manufacturer for the intended installation.

END OF SECTION