

## PART 1 - GENERAL

### 1.1 REFERENCES

The publications listed below form a part of this specification to the extent referenced. The publications are referred to in the text by the basic designation only.

#### FEDERAL SPECIFICATIONS (FS)

FS AA-V-00200 (Rev. B) Venetian Blinds

### 1.2 SUBMITTALS

Submit the following in accordance with Section 01330, "Submittal Procedures."

#### 1.2.1 SD-03, Product Data

- a. Blinds

#### 1.2.2 SD-04, Samples

- a. Blinds

Submit one complete unit of each type specified, labeled for identification. The Contracting Officer will deliver approved samples to the site; if in good condition and otherwise suitable, the samples may be installed in the work. Identification and approval marks shall remain undisturbed until final acceptance. Colors shall be as specified in paragraph entitled "Colors for Slats, Tape, Cords, and Exposed Metal."

### 1.3 DELIVERY AND STORAGE

Deliver the blinds to the site in the manufacturer's original containers with the manufacturer's name and container contents clearly labeled. Store in a safe, dry, clean, and well-ventilated area. Do not open containers until needed for installation unless verification inspection is required.

## PART 2 - PRODUCTS

### 2.1 BLINDS

#### 2.1.1 Blind Units

FS AA-V-00200, Type II, one inch slats, except as modified herein.

Size: Field measure after installation of windows.

#### 2.1.3 Slats

Aluminum for Type II venetian blinds. Slat thickness shall be a nominal .0085 inch.

#### 2.1.4 Ladders

Ladder tapes, 100 percent polyester, woven or braided for Type II. Blinds

#### 2.1.5 Cords

Braided polyester or synthetic fiber, ends heat-fused, terminated with a plastic tassel, or continuous.

#### 2.1.6 Tilting Device

Locate on the right side.

#### 2.1.7 Lifting Cord Locks

Locate on the side opposite the tilting device enabling the blind to stop at any height of window opening.

#### 2.1.8 Color for Slats, Tape, Cords, and Exposed Metal

One color as selected from the manufacturer's standard color samples.

### PART 3 - EXECUTION

#### 3.1 INSTALLATION

Install blinds after the work of other trades, including painting, is substantially done. Install blinds level and in accordance with manufacturer's recommended installation instructions as approved. Isolate metal parts from direct contact with concrete, mortar, or dissimilar metals. Install blinds to the inside of window frames as shown on drawings. Include all hardware, brackets, anchors, fasteners, and accessories necessary for a complete, finished installation.

#### 3.2 LOCATION

Install blinds at all interior and exterior windows with the exception of those located in the stairwells. Provide the required quantity of blinds and carefully check the dimensions of all openings in the facility for exact sizing of the blinds to be provided. Coordinate with Additive Alternate #3.

END OF SECTION